

TECHNICAL DATA SHEET

ATP650

Prime Power*	Standby Power**	Voltage/Ph	Hz/rpm***	PF
650kVA/520 kW	700kVA/560 kW	400/3Ph	50/1500	0.8

Prime power*

Unlimited hours usage with an average load factor of 80% of the published Prime power over each 24 hours period. A 10% overload is available for1 hour in every 12 hours operation.

The generator is working normally at 55 degrees with derating Standby power**

Limited to 500 hours annual usage with an average load factor of 80% of the published Standby power rating over each 24 hour period. Up to 300 hours of annual usage may be run continuously. No overload is permitted on Standby power. Available in 60HZ for all voltage ratings.***

Standard Reference Conditions

Note: Standard reference conditions 40°C (104°F) Air Inlet Temp, 100m (328 ft) A.S.L. 30% relative humidity.

Diesel Generator Set	
Engine Make /Model	PERKINS 2806A-E18TAG2
Alternator Make /Model	Leroy Somer TAL-0473-F
Control Panel	DSE 7320
Base Frame / Silent Canopy	Robust Structure/ Corrosion Resistant
Circuit Breaker Type	3 Pole MCCB (4P Available as optional)
Built in Base Fuel Tank Capacity	1200L
Battery	Maintenance free Lead Acid

Dimensions	Length (cm)	Width (cm)	Height (cm)	Weight (KG)
Close Type	550	180	250	4800
Open Type	490	130	230	4320

LUBRICATION SYSTEM

ENGINE SPECIFICATIONS

Engine Make Model PER		NS 2806A-E18TAG2
No. of Cylinders	6 vertical in-line	
Cycle	4 Strol	ke i la
Aspiration	Turbocharged	
Cooling Method	Water cooled	
Governing Type	Electro	onic
Governing Class	G2 - IS	O 8528 Part 1
Compression Ratio	14.5:1	
Displacement 18.1		
Bore/Stroke	145 x	183 mm
Dynamic Charging Alter- nator	70AM	P, 24V
COOLING SYSTEM		
Total Coolant Capacity (L)		61 L
Cooling Fan Air Flow		852 m³/ min
Radiator Fan Load		9.0 kW
Cooling system design		50 ⁰ C
Heat Radiation to Room (PRP)		45 kW

LODRICATION STSTEIN			
bin-On Full Flow			
PI-CH-4 or ACEA E5			
Dry Element			
37 m ³ /min			
40 m ³ /min			
6.4 kPA			
Industrial Grade			
6.9 kPa			
106 /114 m ³ / min			
<u><</u> 555 ⁰C			

۲ Quality

IMS Certification

Comply with Standards

ISO 3046, BS 5514, DIN 6271, NEMA-MGI, DIN EN, BS 5000, IEC 60034, IEC 60947-2

Powered By:

88 Perkins **Diesel Generator**



BAGHDAD AL SALAM CO. YOUR WAY FOR POWER ATP650 DIESEL GENSET



ATP Gen set is reliable and premium power supply.

- 1. Features & Benefits:
- ATP Gen set is powered by Perkins Engine , the world leader having over 85 years of innovation and excellence, with customers support in 182 countries from 3500 outlets.
- ATP Gen set is powered by Leroy Somer France Alternator, the Global number 1 in Alternators, with over 99 years of Experience, Having 120+ active patents, in over 40 countries and over 80 service centers.
- ATP Gen set is equipped with DSE controller, one of the world's top manufacturers in UK, having over 40 years of excellence, the most advanced and user friendly controller.
- Low fuel consumption, saving on fuel spend
- Compact and rugged design, saving on transport and storage cost
- Designed to occupy less space considering critical applications and cities where space is at a premium.
- Low noise and vibration, considering critical applications where noise level matters
- Easy maintenance and long service intervals, saving on maintenance cost
- Subject to rigorous tests including load acceptance, cooling, vibration and noise level prior shipment to customer.
- Simple to operate and environment friendly in worst ambient conditions
- Equipped with built-in fuel tank sufficient for 8 to 10 hours of operations.
- Fully Engineering wide range of optional accessories available.

(Contd.)





TECHNICAL DATA SHEET

ATP650



PERKINS Engine 2806A-E18TAG2



Lerov Somer TAL-0473-F



DSE7320 MKII AUTO START & AUTO MAINS



IRAQ -- BAGHDAD

Mob : +964 7901 908806 E-mail: baghdadalsalamco@yahoo.com : info@baghdadalsalam.com

BAGHDADALSALAMCO

BAGHDADALSALAMCO

Engine	Fuel System
-	

Recommended Fuel	Class A2 Diesel
Fuel Consumption Standby	143 L/hr
Fuel Consumption 100% PRP	132 L/hr
Fuel Consumption 75% PRP	97 L/hr
Fuel Consumption 50% PRP	66 L/hr

ALTERNATOR SPECIFICATIONS

Alternator Make /Model	Leroy Somer TAL-047-F
AVR Model	R150
Number of Poles	4
Number of Winding Leads	6
Type of Bearing	Single Bearing
Insulation Class - Temp Rise	Cont. H - 125/40 C
Ingress Protection Rating	IP 23
Excitation System	Self Excited
Voltage Regulation	+ 1%
Harmonic Coefficient THF	< 2%
Tel. influence TIF Cooling air flow	< 50 0.9 m ³ / Sec

Controller Make & Model		DeepSea 7320	
Operation Mode		AMF	
Display		aphic Back-lit LCD 32x64) pixles	
Ingress Protection Rating		IP65	
Binary Inputs/Outputs		9/8	
Analog Inputs		4	
Measurement		Vac, A, Hz, kVA, kW, Vdc	
Event Log		Alarms log, Hrs log	
Communication		USB	
Please refer to Controller Data Sheet for mo	ore d	letails	

Enclosure Type	Acoustic & Weather Proof
Drainage	Fuel and Water Drainage Provision
Transportation	Tested Single Point Lifting Facility & Forklift Pockets
Ingress Protection	IP 23
Lifting	ISO Standard Lifting
Canopy RAL Color	RAL 9010 - Powder coated
Base frame RAL Color	RAL 9005 - Powder coated
Noise Pressure level @	85 @ 1 to 3 m

BAGHDADALSALAM

4. OPTIONAL FEATURES A. Engine

Heavy-Duty Air Filter

2. WARRANTY POLICY:

60 % of the load.

warranty policy

3. DOCUMENTAION

•

- **Coolant Heater**
- Lubricant Oil Heater
- Fuel and Water Separator
- Lube Oil Rotary Pump

B. Alternator

with Genset.

- Anti Condensation Heater
- PMG + AVR
- **Double Bearing Alternator**
- **RTDs For Bearing and Winding**
- C. Cooling System:
- 55 degree Radiator
- Remote Radiator

D. Control System:

- AMF / Parallel
- **Remote Annunciators**
- 4 p manual/Motorized Circuit breaker
- E. Automatic Transfer Switch (ATS):
- Contractor or Breaker type ATS
- Motorized changeover type ATS

F. Start Battery:

- Nickel-cadmium battery
- Maintenance-free battery
- Battery charger and selector switch
- Charging current meter

G. Exhaust Muffler:

- **Residential grade**
- Critical grade
- Hospital grade
- H. Available for voltages :

400/230V,480/277V,380/220V,440/254V, 416/240V,220/127V, 208/120V

Due to continuous research & product development, we reserve the right to change specification with out notice

BAGHDADALSALAMCO



Baghdad Al salam Generator technology

generator must not be working less than

Wearing parts (filters), incorrect man-

made operation, Back up Genset mainte-nance failures are excluded from the

For more details please refer to www.baghdadalsalam.com

Operation and Maintenance Manual, GAD, Wiring Diagram & FAT Report are Accompanied

has a warranty 1000 hours or one year whichever occurs first, from any manufacturing defect (except for bad fuel usage or misuse). Regarding that the

BAGHDAD AL SALAM CO.